

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF PULASKI COUNTY WATER)	
DISTRICT NO. 1 FOR A DEVIATION FROM THE)	
REQUIREMENTS OF 807 KAR 5:066, SECTION)	CASE NO. 89-279
5(4), REGARDING WATER STORAGE)	

O R D E R

By application received September 27, 1989, Pulaski County Water District No. 1 ("Pulaski Water") requested a deviation from Commission Regulation 807 KAR 5:066, Section 5(4), which provides that each utility shall provide water storage to ensure a minimum of one day's supply of its average daily water usage. Pulaski Water states in its application that its average daily water usage, including unaccounted-for water, is approximately 169,000 gallons, and its current water storage capacity is 75,000 gallons.

The Commission, having reviewed the application and being advised, finds that:

1. Pulaski Water is not in compliance with the requirements of Commission Regulation 807 KAR 5:066, Section 5(4).

2. Because of the time needed to plan, finance, and implement a program to construct water storage facilities, Pulaski Water should be given until November 1, 1992 to bring it within compliance of the Commission's water storage requirements.


IT IS THEREFORE ORDERED that:


1. Pulaski Water be and it hereby is given until November 1, 1992 to comply with the provisions of 807 KAR 5:066, Section 5(4).

2. Pulaski Water shall take all necessary actions to bring its water storage facilities within compliance of the Commission regulations prior to the expiration date of the deviation herein granted.

Done at Frankfort, Kentucky, this 30th day of October, 1989.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:

Executive Director